



322/817/529/2016

Gdańsk, 19-12-2016

Profile VOX sp. z o.o. sp.k.
ul. Gdyńska 143
62-004 Czerwonak

Subject: Hygienic Approval No. 69/322/74/2016 dated 12-02-2016

In response to a letter of Profile VOX sp. z o.o. sp. k. dated 12-12-2016, the Department of Environmental Toxicology at the Medical University of Gdańsk reports that KERRADECO and KERRADECO BIO Wall Systems are suitable for rooms in health care facilities. The condition is that the Wall System must not cover more than 50% of the total area of the room. The above-mentioned limitation does not apply in other types of rooms such as bathrooms, hallways.

KIEROWNIK
Zakładu Toksykologii Środowiska
z up. Janina Kopyce
prof. dr hab. Lidia Wołka